NIST Technical Study

Sofa Super Store Fire

Draft Report for Public Comment

Charleston, South Carolina October 28, 2010

Dr. William Grosshandler Mr. Nelson Bryner

National Institute of Standards and Technology
U.S. Department of Commerce



Objectives - Technical Study Team

- 1) To determine why and how the fire spread so quickly
- 2) To study conditions within structure, in terms of temperature, oxygen concentration, smoke movement, & tenability*
- 3) To identify specific areas in model building and fire codes**, standards and practices that warrant revision.
- * Ability to escape unassisted
- **Codes used as national models for building and fire regulations. State and local jurisdictions have the option of incorporating some or all of model code provisions



Tasks-

- 1) Identification of technical issues (why rapid fire spread) and major hypotheses requiring examination.
- 2) Data collection design records, video and photographic data, radio transmissions, field data, and interviews.
- 3) Analysis and comparison of building and fire codes and practices, and review and analysis of practices used in operation of the building.
- 4) Simulation and analysis of phenomena, including fire spread, smoke movement, tenability, and operation of active and passive fire protection systems.



Views of **Building High Bay Warehouse** Non-Fire Roll Up Door Breezeway Repair Shop Repair Loading Shop Dock Fire Door Area Non-Fire Roll Up Door Rear of Store Holding Area Double Sales Offices and Support Areas Doors Roll-Up Fire Door Roll-Up __ Fire Door **Main Showroom** East West Showroom Roll-Up Showroom Roll-Up _ Fire Door Roll-Up Fire Door Roll-Up North Front of Store

(main entrance)

NIST Image







Overall Time Line

<u>Time</u>	<u>Event</u>				
6:56 pm	- Fire observed at rear of store				
	- store employee discharges port. fire extinguisher				
	- fire reported to 911 Center				
7:08	 Dispatch receives report of fire behind store 				
7:09	- Engines 10 & 11, Ladder 5, & Battalion Chief dispatched				
7:12	 Engines 10 & 11, Ladder 5, Assistant & Battalion Chief on scene 				
7:13	 Assistant Chief opens door and locates fire on loading dock 				
	 Loading dock fully involved with fire 				
	- Fire spreads to holding area and warehouse				
7:16	- Fire Chief arrives on scene				
7:20	- Engine 10 at loading dock receives water from Engine-12				




Overall Timeline continued

<u>Time</u>	<u>Event</u>
7:27 pm	 Engine-11 at store front receives water from Engine-16 Trapped employee calls 911
7:31	 "Lost or trapped inside " radio call Employee rescued "Mayday"
	 Fire Chief "we need to evacuate building" Engine air horns sounded to evacuate building
7:35	- front windows vented
7:36	brown smoke pours out of broken windowsblack smoke rolls out front windows
7:37	- fire rolls out front windows
7:51	- Portion of main showroom roof collapses
10:00	- Fire under control












Computer Simulation

- 1) Uses data on floor plan, materials of construction, opening of doors and windows, fuel load, weather, etc.
- 2) Each computer simulation requires about 4 days to run (required > 250 runs)
- 3) Compared simulation results to photographs, observations, interviews, and data. Most consistent simulation = most probable fire sequence
- 4) Multiple scenarios including impact of sprinklers, front windows intact, and roof openings
- 5) Output temperatures, oxygen concentrations, and smoke & flame within structure



Computer Simulation – overall structure






Computer Simulation - Floor Plan with merchandise





Temperature in the Sofa Super Store Computer Simulation




Temperature Slice - 5 ft above floor

20 x real time



Smoke and Fire Spread in the Sofa Super Store

Computer Simulation



Smoke & Fire Slice Elevation - 5 ft above floor

20 x real time



Oxygen in the Sofa Super Store

Computer Simulation



Oxygen Elevation - 5 ft above floor



Key Findings – Initial Conditions

- 1) Large amount of foam-filled furniture in showrooms (480 GJ), loading dock (130 GJ), and warehouse (840 GJ)*
- 2) Large open areas

Showroom		Warehouse	Loading Dock
Main	17100 ft ²	15800 ft ²	2220 ft ²
West	7020 ft ²		
East	6940 ft ²		

3) No automatic water sprinklers anywhere in store

* 100 gallons of gasoline contains about 12 GJ of energy



Key Findings – Fire Spread into Showrooms

- 1) Smoke and flames entered the holding area through the open roll-up door (non-fire activated).
- 2) Fire spread was not visible from the main and west showroom during the early stages (5 to 10 minutes after fire department arrived).
- 3) Smoke and flames flowed from the holding area into the space above the main showroom drop ceiling.
- 4) Fire spread into rear of main showroom. Fire spread slowed by limited oxygen, ventilation limited.
- 5) Layer of smoke and unburned fuel collected under ceiling in main and west showrooms; smoke filled floor to ceiling



Key Findings – Fire Spread into Showrooms

- 6) Fire began to slowly move towards front of store.
- 7) Front windows broken out.
- 8) Additional oxygen flowed in through broken windows and fire spread rapidly to front of main showroom (west side).
- 9) Fire quickly spread across front of store, moved toward east showroom, into west showroom, and then rear of main showroom (east side).



Key Findings – Showroom Conditions

Simulation time when conditions became untenable *-

		Temperature greater than 120 C or 250 F	Oxygen less than 0.12
West Showroom -			
	Front	23.3 min	26.6 min
	Rear	22.5 min	25 min
West Main Showroom -			
	Front	15 min	21 min
	Rear	15 min	21 min
East Main Showroom -			
	Front	22.5 min	23.3 min
	Rear	21 min	23.3 min

^{*} Ability to escape unassisted



Non-Sprinklered and Sprinklered Simulations

No sprinklers were present in Sofa Super Store

Computer Simulations



Temperature Slice - 5 ft above floor



Non-sprinklered

Sprinklers inside Loading Dock

Sprinklers activate at 50 seconds and 75 seconds



Key Findings – Fire Spread

Sprinkler Scenario Simulation

- 1) Sprinklers controlled fire on loading dock
- 2) Sprinklers activated at 50 s and 75 s
- 3) Conditions remained tenable throughout showrooms



Study Recommendations:

Furniture Stores represent unique fire hazards:

- a) large quantities of foam-filled furniture
- b) large open space
- 1) NIST recommends: All state and local jurisdictions should adopt model building and fire code covering new and existing high fuel-load mercantile occupancies.

Hazardous conditions identified by routine inspections by skilled inspectors with appropriate follow –up

- a) lack of sprinklers
- b) non-fire roll-up door
- c) wood framing of loading dock
- 2) NIST recommends: All state and local jurisdictions implement aggressive fire inspection and enforcement programs and ensure that inspectors are professionally qualified to a national standard.



Study Recommendations:

Lack of sprinklers

- a) no sprinklers in loading dock, showrooms, or warehouse.
- b) sprinklers inside loading dock controlled fire in less than 1.5 minutes
- 3) NIST recommends: All state and local authorities adopt and enforce model code requirements for sprinkler systems
 - a) for all new commercial retail furniture stores regardless of size; and
 - b) for existing retail furniture stores with any single display area of greater than 190 m² (2000 ft²).



Study Recommendations:

Research Recommendations

- 1) Upholstered Furniture Flame Spread
 - a) prediction of ignition,
 - b) prediction of fire spread, and
 - c) smoke and toxic gas generation
- 2) Improving Fire Barriers
 - a) fire spread through walls
 - b) fire spread through doors, glass, wood, & metal
 - c) perf. of roll-up doors in actual fires and extended service
- 3) Decision aids for resource allocation
 - a) computer-aided decision tools
 - b) computer models to assist communities in allocating resources
- 4) Ventilation of Burning Structures
 - a) characterize how vent. affects growth and spread of fire
 - b) provide fire service with guidance on when and how to use ventilation to improve fire conditions
- 5) Performance Metrics for Fire Protection
 - a) performance and effectiveness metrics for community fire protections
 - b) survey effectiveness of existing fire services



NIST welcomes comments on Draft Report

Web site to view draft final report:

http://www.nist.gov/el/investigations/bfrl-investigations.cfm

(All comments received by December 2, 2010 will be considered prior to issuing the NIST Final Report)

Submit comments to:

E-mail: firesafety@nist.gov

FAX: (301) 975-4052

Mail address:

NIST Technical Study: Sofa Super Store National Institute of Standards and Technology 100 Bureau Drive, Stop 8660 Gaithersburg, MD 20899-8660



Next Steps-

- 1) Consider and incorporate public comments
- 2) NIST will work with model code organizations to incorporate recommendations in national model code
- 3) NIST will work with the major organizations representing state and local governments, including building and fire officials, and fire fighters to incorporate recommendations
- Develop new performance standards and test protocols for fire protection systems
- 5) Conduct additional research in
 - a) Upholstered Furniture Flame Spread -
 - b) Improving Fire Barriers
 - c) Decision aids for resource allocation
 - d) Ventilation of Burning Structures
 - e) Performance Metrics for Fire Protection

